

設備名稱：無熔線斷路器		型號（主型式）如下所示				
Equipment name		Type designation (Type)				
FAZ 4P 63AF 60Hz D type 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A,13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, Icn = 10KA at 380V, Ics = 7.5A at 380V						
單元 Unit	限用物質及其化學符號					
	Restricted substances and its chemical symbols					
	鉛Lead (Pb)	汞Mercury (Hg)	鎘Cadmium (Cd)	六價鉻 Hexavalent chromium (Cr <sup>+6</sup> )	多溴聯苯 Polybrominated biphenyls (PBB)	多溴二苯醚 Polybrominated diphenyl ethers (PBDE)
塑膠外殼	○	○	○	○	○	○
操作機構	○	○	○	○	○	○
接續端子	○	○	○	○	○	○
內部接點	○	○	○	○	○	○
電路板	○	○	○	○	○	○
比流器	○	○	○	○	○	○
消弧室	○	○	○	○	○	○
備考1. “超出0.1 wt %” 及 “超出0.01 wt %” 係指限用物質之百分比含量超出百分比含量基準值。 Note 1 : “Exceeding 0.1 wt %” and “exceeding 0.01 wt %” indicate that the percentage content of the restricted substance exceeds the reference percentage value of presence condition.						
備考2. “○” 係指該項限用物質之百分比含量未超出百分比含量基準值。 Note 2 : “○” indicates that the percentage content of the restricted substance does not exceed the percentage of reference value of presence.						
備考3. “-” 係指該項限用物質為排除項目。 Note 3 : The “-” indicates that the restricted substance corresponds to the exemption.						

## 系列型式:

FAZ 1P 63AF 60Hz B type 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A,13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, Icn = 10kA at 220V, Ics = 7.5kA at 220V

FAZ 1P 63AF 60Hz C type 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A,13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, Icn = 10kA at 220V, Ics = 7.5kA at 220V

FAZ 1P 63AF 60Hz D type 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A,13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, Icn = 10kA at 220V, Ics = 7.5kA at 220V

FAZ 1P+N 63AF 60Hz B type 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A,13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, Icn = 10kA at 220V, Ics = 7.5kA at 220V

FAZ 1P+N 63AF 60Hz C type 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A,13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, Icn = 10kA at 220V, Ics = 7.5kA at 220V

FAZ 1P+N 63AF 60Hz D type 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A,13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, Icn = 10kA at 220V, Ics = 7.5kA at 220V

FAZ 2P 63AF 60Hz B type 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A,13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, Icn = 10kA at 380V, Ics = 7.5kA at 380V

FAZ 2P 63AF 60Hz C type 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A,13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, Icn = 10kA at 380V, Ics = 7.5kA at 380V

FAZ 2P 63AF 60Hz D type 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A,13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, Icn = 10kA at 380V, Ics = 7.5kA at 380V

FAZ 3P 63AF 60Hz B type 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A,13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, Icn = 10kA at 380V, Ics = 7.5kA at 380V

FAZ 3P 63AF 60Hz C type 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A,13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, Icn = 10kA at 380V, Ics = 7.5kA at 380V

FAZ 3P 63AF 60Hz D type 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A,13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, Icn = 10kA at 380V, Ics = 7.5kA at 380V

FAZ 3P+N 63AF 60Hz B type 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A,13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, Icn = 10kA at 380V, Ics = 7.5kA at 380V

FAZ 3P+N 63AF 60Hz C type 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A,13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, Icn = 10kA at 380V, Ics = 7.5kA at 380V

FAZ 3P+N 63AF 60Hz D type 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A,13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, Icn = 10kA at 380V, Ics = 7.5kA at 380V

FAZ 4P 63AF 60Hz B type 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A,13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, Icn = 10kA at 380V, Ics = 7.5kA at 380V

FAZ 4P 63AF 60Hz C type 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A,13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, Icn = 10kA at 380V, Ics = 7.5kA at 380V