

設備名稱：無熔線斷路器 ， 型號（型式）：如下所示

Equipment name

Type designation (Type)

FAZ-NA 3P 40AF 60Hz D type 0.5A, 1A, 1.5A, 2A, 3A, 4A, 5A, 6A, 7A, 8A, 10A, 13A, 15A, 16A, 20A, 25A, 30A, 32A, 35A, 40A Ics=7.5kA at 220V, Icu=15kA at 220V

FAZ-NA 1P 40AF 60Hz C type 0.5A, 1A, 1.5A, 2A, 3A, 4A, 5A, 6A, 7A, 8A, 10A, 13A, 15A, 16A, 20A, 25A, 30A, 32A, 35A, 40A Ics=7.5kA at 220V, Icu=15kA at 220V

FAZ-NA 1P 40AF 60Hz D type 0.5A, 1A, 1.5A, 2A, 3A, 4A, 5A, 6A, 7A, 8A, 10A, 13A, 15A, 16A, 20A, 25A, 30A, 32A, 35A, 40A Ics=7.5kA at 220V, Icu=15kA at 220V

FAZ-NA 2P 40AF 60Hz C type 0.5A, 1A, 1.5A, 2A, 3A, 4A, 5A, 6A, 7A, 8A, 10A, 13A, 15A, 16A, 20A, 25A, 30A, 32A, 35A, 40A Ics=7.5kA at 220V, Icu=15kA at 220V

FAZ-NA 2P 40AF 60Hz D type 0.5A, 1A, 1.5A, 2A, 3A, 4A, 5A, 6A, 7A, 8A, 10A, 13A, 15A, 16A, 20A, 25A, 30A, 32A, 35A, 40A Ics=7.5kA at 220V, Icu=15kA at 220V

FAZ-NA 3P 40AF 60Hz C type 0.5A, 1A, 1.5A, 2A, 3A, 4A, 5A, 6A, 7A, 8A, 10A, 13A, 15A, 16A, 20A, 25A, 30A, 32A, 35A, 40A Ics=7.5kA at 220V, Icu=15kA at 220V

單元 Unit	限用物質及其化學符號 Restricted substances and its chemical symbols					
	鉛Lead (Pb)	汞Mercury (Hg)	鎘Cadmium (Cd)	六價鉻 Hexavalent chromium (Cr <sup>+6</sup> )	多溴聯苯 Polybrominated biphenyls (PBB)	多溴二苯醚 Polybrominated diphenyl ethers (PBDE)
塑膠外殼	○	○	○	○	○	○
操作機構	○	○	○	○	○	○
接續端子	○	○	○	○	○	○
內部接點	○	○	○	○	○	○
電路板	○	○	○	○	○	○
比流器	○	○	○	○	○	○
消弧室	○	○	○	○	○	○

備考1. “超出0.1 wt %”及“超出0.01 wt %”係指限用物質之百分比含量超出百分比含量基準值。

Note 1 : “Exceeding 0.1 wt %” and “exceeding 0.01 wt %” indicate that the percentage content of the restricted substance exceeds the reference percentage value of presence condition.

備考2. “○”係指該項限用物質之百分比含量未超出百分比含量基準值。

Note 2 : “○” indicates that the percentage content of the restricted substance does not exceed the percentage of reference value of presence.

備考3. “—”係指該項限用物質為排除項目。

Note 3 : The “—” indicates that the restricted substance corresponds to the exemption.